

Emission Test Certificate

Tuesday October 2nd, 2007

Supplier: The Laminex Group

21 Trewin St

Wendouree Victoria 3355

Sample Description: Raw Particleboard

Date Tested: September 2007

Test Method: ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Raw Particleboard

Total Volatile Organic Compound Emission Rate: 0.15 mg/m²/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m³ as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project CV070820